

Overtime Report October, 2024

Operator	Date	Time	OT Hrs.	Alarm Call	Operator Response
John Gibson	10/7/2024	18:37	2	FF Common High Alarm	Logged in remotely, both filters in a wash cycle. Purge tank low. Shut down FFb remotely. Responded to the plant and restarted FFb. Went back into wash cycle after startup complete. Not enough purge tank water to complete the wash cycles. Shut down plant processes.
Sean Bernard	10/8/2024	23:14	2	FF Common High Alarm	Responded to the plant. Purge pump had faulted, reset purge pump breaker and cleared alarms. Cleaned turbidity meters, system back online.
Sean Bernard	10/15/2024	4:59	2	FF Common High Alarm	Responded to the plant. Purge pump had faulted, reset purge pump breaker and cleared alarms. Brought system back online.
John Gibson	10/24/2024		2		Lift station #1 slide rail and pump install.
John Gibson	10/25/2024		2		Lift station #1 slide rail and pump install.
Sean Bernard	10/24/2024		2		Lift station #1 slide rail and pump install.