

Overtime Report May, 2024

Operator	Date	Time	OT Hrs.	Alarm Call	Operator Response
John Gibson	5/4/2024		2		Weekend duties during discharge season. Daily sampling and analysis at monitoring location EFF-002. Creek readings, setting discharge flow rates, record data.
John Gibson	5/5/2024		2		Weekend duties during discharge season. Daily sampling and analysis at monitoring location EFF-002. Creek readings, setting discharge flow rates, record data.
Sean Bernard	5/11/2024		2		Weekend duties during discharge season. Daily sampling and analysis at monitoring location EFF-002. Creek readings, setting discharge flow rates, record data.
Sean Bernard	5/12/2024		2		Weekend duties during discharge season. Daily sampling and analysis at monitoring location EFF-002. Creek readings, setting discharge flow rates, record data.
Sean Bernard	5/21/2024	22:45	2	Coagulant loss of flow	Responded to the plant to reset restart systems.
Sean Bernard	5/22/2024	19:00	3	Fuzzy Filter common high alarm	Responded to the plant. On arrival, proceeded to reset and restart the systems. Successfully restarted the SAF system. Encountered an issue with FF b, which was stuck in a purge cycle and unable to reset the purge pump. As a result, the plant processes were shut down.