

## Overtime Report November, 2024

Operator	Date	Time	OT Hrs.	Alarm Call	Operator Response
Sean Bernard	11/21/2024	20:34	2	Storm water high alarm.	Responded to the plant. Storm system not keeping up with the flow. Hooked up manual 8hp trash pump system to bypass the storm pump. Checked on plant processes.
Sean Bernard	11/22/2024	5:45	2	Storm water high alarm. Storm pump faulted.	Responded to the plant. Storm pump not operating, switched pump from auto to manual mode. Still not operational. Removed pump and installed backup Flygt 5hp pump.
Sean Bernard	11/25/2024	11:20		Surge tank high alarm	Responded to the plant. FF A in stuck in a wash cycle due to purge pump alarm. Reset alarms and restarted the filter.
Sean Bernard	11/30/2024		2		Weekend duties during discharge season. Daily sampling and analysis at monitoring location EFF-002. Creek readings, setting discharge flow rates, record data.
John Gibson	11/23/2024		2		Weekend duties during discharge season. Daily sampling and analysis at monitoring location EFF-002. Creek readings, setting discharge flow rates, record data.
John Gibson	11/24/2024		2		Weekend duties during discharge season. Daily sampling and analysis at monitoring location EFF-002. Creek readings, setting discharge flow rates, record data.